

Results:

	U-Factor	CR	SHGC	VT	Dividers	Tint	Low-E	Glazing Description
001	<b>0.51</b>	<b>35</b>	<b>0.32</b>	<b>0.53</b>	N	Clear	2	3/16" E172 / 3/16" Clear 0.625" Gap - Air Fill Standard Aluminum Spacer COG U-Factor = 0.303 COG Temperature = 52.9°F
			<b>0.29</b>	<b>0.47</b>	<1"	Clear	2	
			<b>0.26</b>	<b>0.42</b>	>1"	Clear	2	
			<b>0.38</b>	<b>0.53</b>	N	Clear	3	
			<b>0.34</b>	<b>0.47</b>	<1"	Clear	3	
			<b>0.31</b>	<b>0.42</b>	>1"	Clear	3	
Note: Sill Frame #030023								

	U-Factor	CR	SHGC	VT	Dividers	Tint	Low-E	Glazing Description
002	<b>0.50</b>	<b>36</b>	<b>0.37</b>	<b>0.52</b>	N	Clear	3	1/4" Clear Laminate / 1/4" E172 0.500" Gap - Air Fill Standard Aluminum Spacer COG U-Factor = 0.291 COG Temperature = 53.6°F
Note: Sill Frame #030023								

	U-Factor	CR	SHGC	VT	Dividers	Tint	Low-E	Glazing Description
003	<b>0.54</b>	<b>36</b>	<b>0.50</b>	<b>0.55</b>	N	Clear	3	1/4" Clear Laminate / 1/4" Comfort E2 0.500" Gap - Air Fill Standard Aluminum Spacer COG U-Factor = 0.341 COG Temperature = 51.0°F
Note: Sill Frame #030023								

	U-Factor	CR	SHGC	VT	Dividers	Tint	Low-E	Glazing Description
004	<b>0.50</b>	<b>36</b>	<b>0.34</b>	<b>0.50</b>	N	Clear	3	1/4" Clear Laminate / 1/4" E170 0.500" Gap - Air Fill Standard Aluminum Spacer COG U-Factor = 0.289 COG Temperature = 53.7°F
Note: Sill Frame #030023								

Results:

	U-Factor	CR	SHGC	VT	Dividers	Tint	Low-E	Glazing Description
005	<b>0.51</b>	<b>35</b>	<b>0.33</b>	<b>0.55</b>	N	Clear	2	3/16" E172 / 3/16" Clear 0.625" Gap - Air Fill Standard Aluminum Spacer COG U-Factor = 0.303 COG Temperature = 52.9°F
			<b>0.30</b>	<b>0.49</b>	<1"	Clear	2	
			<b>0.27</b>	<b>0.43</b>	>1"	Clear	2	
			<b>0.39</b>	<b>0.55</b>	N	Clear	3	
			<b>0.35</b>	<b>0.49</b>	<1"	Clear	3	
			<b>0.31</b>	<b>0.43</b>	>1"	Clear	3	
Note: Sill Frame #030024								

	U-Factor	CR	SHGC	VT	Dividers	Tint	Low-E	Glazing Description
006	<b>0.49</b>	<b>36</b>	<b>0.37</b>	<b>0.53</b>	N	Clear	3	1/4" Clear Laminate / 1/4" E172 0.500" Gap - Air Fill Standard Aluminum Spacer COG U-Factor = 0.291 COG Temperature = 53.6°F
Note: Sill Frame #030024								

	U-Factor	CR	SHGC	VT	Dividers	Tint	Low-E	Glazing Description
007	<b>0.53</b>	<b>36</b>	<b>0.52</b>	<b>0.56</b>	N	Clear	3	1/4" Clear Laminate / 1/4" Comfort E2 0.500" Gap - Air Fill Standard Aluminum Spacer COG U-Factor = 0.341 COG Temperature = 51.0°F
Note: Sill Frame #030024								

	U-Factor	CR	SHGC	VT	Dividers	Tint	Low-E	Glazing Description
008	<b>0.49</b>	<b>36</b>	<b>0.35</b>	<b>0.52</b>	N	Clear	3	1/4" Clear Laminate / 1/4" E170 0.500" Gap - Air Fill Standard Aluminum Spacer COG U-Factor = 0.289 COG Temperature = 53.7°F
Note: Sill Frame #030024								

	U-Factor	CR	SHGC	VT	Dividers	Tint	Low-E	Glazing Description
TEST	<b>0.49</b>	<b>35</b>	<b>0.33</b>	<b>0.55</b>	N	Clear	2	3/16" E172 / 3/16" Clear 0.670" Gap - Air Fill Standard Aluminum Spacer COG U-Factor = 0.306 COG Temperature = 52.8°F
Note: Sill Frame #030024								